

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:54 am

PWS ID: UTAH08020 **Name:** FILLMORE SUBDIVISION - JOES VALLEY
Legal Contact: JOES VALLEY CULINARY WATER COMF **Rating:** Approved
DAN M VERDE **Rating Date:** 11/15/2001
Address: PO BOX 42 **Activity Status:** Active
ORANGEVILLE, UT 84537
Phone Number: 435-381-5258
City Served (Area):
County: EMERY COUNTY
System Type: Non-community **Last Inv Update:** 07/07/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 08/21/2008 **Total Dsgn Cap:**
Population: 100 **Surveyor:** GARY XANTHOS **Total Emerg Cap:**
Oper Period: 5/1 to 9/30

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	VERDE, DAN M				

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	69
			69 Total Svc Connections

Storage

Total Storage: 15,840 GAL **Number of Units:** 2 **Adequate Capacity:** YES

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	12000 GALLON TANK	Ground	10,560 GAL	Steel		A	NO
ST002	13000 GALLON TANK	Ground	5,280 GAL	Steel		A	NO

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	JOES VALLEY WELL	Active	WL	16		201 GPM	Yes	GW	Seasonal	5/1 to 9/30	

*Reports measured flow for wells, approved design capacity for all other sources.